

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0047:013 Page 1 of 1

CATEGORY: Door Closers/ HOLDERS

LISTEE: Rixson-Firemark, 1902 Airport Rd., Monroe, NC 28110
Contact: *Jeff Trull (704) 283-2101 Fax (704) 226-6198

DESIGN: Model FM972S, FM972H, FM972U. Designed for special door applications requiring positive latch, hold-open and automatic release to close by a remote smoke detector switch, ionization fire detector, or sprinkler system. Intended for use for heavy swing, overhead rolling, vertical or horizontal sliding, guillotine or service counter and conveyor opening doors; fire damper; and self-closing windows. See listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire-rated door closer/holder.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**